Development: Site A		Address:		
En	Engineer's Name:	Date:		
General Plan Requirements				
	 □ Eight sets of plans plus original shall be submitted □ Minimum sheet size shall be 24" x 36" unless otherwise approved □ Set shall be comprised of separate sheets as listed below unless of Committee at the pre-application scoping session □ All plans shall be stamped by Commonwealth of Massachusetts-related Land Surveyor, and/or Professional Landscape Architect □ All plans oriented so that north arrow points generally to the top of All plans shall have a title block comprised of the following: □ Project Title □ Sheet Title □ Sheet Number □ Registrant Stamp (PE, PLS, LA) □ Engineers name, address, fax and telephone number □ Graphical scale at 1" = 40' or less □ Plan Issue Date □ Plan Revision Date(s) 	otherwise approved by the Site Plan		
	 □ Traffic Impact and Access Study (TIAS) to be submitted with application □ Storm Water Management Report to be submitted with application □ Sewer Connection/Extension Permitting (if required) □ MEPA waiver West Plant (if required) 			
<u>Cc</u>	Cover Sheet			
	 □ Project name / title □ Street number and/or lot number (for new buildings, engineering w □ Assessor's map and parcel number(s) □ Name and address of property owner □ Name, address, telephone and fax number of engineer □ Name, address, telephone and fax number of the developer □ Revision Date Block □ Zoning District □ Zoning Requirements Table-"Required vs. Provided" □ Lot Size □ Lot Frontage 	vill assign a street number prior to a	pproval)	
	□ Side Yard Setback □ Front Yard Setback □ Rear Yard Setback □ Building Height □ Lot Coverage □ Distance from Residential District □ Parking Spaces □ Compact Parking Spaces □ Handicap Parking Spaces □ Parking Lot Setback □ Parking Lot Perimeter Planting □ Parking Lot Interior Planting □ Landscaping Requirements □ Locus Map (Show all roads and available building information with	nin 1000 feet)		
	☐ Planning Board signature block (7 lines) ☐ Plan Index with latest revision date of each plan			

Existing Conditions Plan

	Name of Surveyor Date of survey Property lines with bearings and distances Monuments Easements with bearings and distances Name of all abutters Street names Plan survey datum shall be the North American Vertical Datum of 1988 (NAVD 1988) and this reference shall be
	shown on the plans. Benchmark locations minimum of two within 200 feet of the site shown on the plans. Existing Buildings and Structures Area of building Number of stories Principal use Setbacks from property lines Floor elevations
	 □ Door locations with sill elevations Existing Topography: □ Contours at 2' intervals (1' contours or additional spot grades if site is flat) □ Overhead and underground utilities including but not limited to water, sewer, drainage, electric, telephone, cable TV, gas, septic systems, detention structures, wells □ Existing parking/paved areas including pavement type (parking, walkways, etc.) □ Adequate utility information outside the site to verify proposed utility connections □ All utility pipe types, sizes, lengths, and slopes □ All utility structure information including rim and invert elevations □ All existing easements within 50 feet of property line-Identify any utility within the easement □ All existing utility easements with bearings and distances □ Existing pavement markings within site and on connecting roads □ Existing features such as walls, curbing, landscaping, trees, walks, fences, trees over 12" caliper, lighting, signs, loading areas, dumpster locations, etc
	Wetlands, floodplain, water protection district delineation including offsets and buffer zones Test pit locations including groundwater depths Historic buildings within 250 feet
Co	nstruction/Layout Plan (show appropriate information from Existing Conditions Plan)
	Proposed Buildings and Structures Area of building or additions Number of stories Principal use Floor elevations Door locations with sill elevations Setback dimensions from property lines Proposed Topography including but not limited to: Proposed contours at 2' intervals Parking lot setbacks to property line Parking lot grades shall not exceed 5% or be less than 0.5% Parking spaces (delineated and dimensioned) Handicap parking Handicap parking Handicap access Wheelchair ramps Sidewalks Pavement type(s) Curb type(s) and limits Granite curb at entrance to layout line

Z:\Common\New Engineering\Departments\Site Plan Com\Admin\Checklists\Updated Checklists 2015\Subdivision Plan Checklist - Updates.doc Page 2 of 5

	□ Lighting □ Signs (include sign schedule) □ Pavement markings □ Loading areas □ Walls □ Fences □ Landscape areas □ Dumpster(s) Critical dimensions including aisle widths, parking stall dimensions, curb radius etc Grading at entrance-show spot grades if required Emergency Vehicle Access Truck Access (WB-50 unless otherwise approved by City Engineer) Snow Storage Area
	Show limit of work within City right-of-way-sawcut Construction notes including the following notes: The contractor shall be properly licensed and bonded with the City prior to construction. Any minor modifications (as determined by the City Engineer) to the information shown on the approved site plans shall be submitted to the City Engineer as a Minor Plan Revision for approval prior to the work being performed. Any work and materials to be placed within the City right-of-way shall conform to the City of Marlborough requirements All handicap parking, ramps, and access shall conform to MAAB & ADA requirements All erosion control measures shall be in place prior to construction. Erosion Control shall conform to the City of Marlborough Conservation Commission requirements as stated in the Order of Conditions. (refer to Erosion Control Plan if part of submission) All pavement markings and signs shall conform to MUTCD requirements The contractor shall obtain a Street Opening Permit prior to any construction within the City right-of-way
<u>Uti</u>	ity and Grading Plan (show appropriate info. from Existing Conditions and Construction Plan)
_	All proposed utilities including but not limited to Water, Sewer, Drainage, Electric, Telephone, Cable TV, Gas, Lighting, Septic Systems, Detention Structures Adequate utility information outside the site to verify proposed utility connections All utility pipe types, sizes, lengths, and slopes All utility structure information including rim and invert elevations All water services, hydrants, gates, shutoffs, tees Utilities shall be underground if possible All transformer locations Required utility easements with bearings and distances Minimize utility crossings (show locations of crossings and verify clearance) 5' horizontal separation between all utilities (10' between water and sewer) Utility crossing and separation including gas, underground power and communications must be installed as shown or get approval from DPW prior to changes
	See Recommended Force Main Requirements if force main is proposed Sewer Connection/Extension Permitting (if any of the following apply) Proposed site generates industrial waste Proposed flows exceed 15,000 gallons/day Pump Station
	 □ Extension of sewer main Sewer system □ Show and label service connections for each building. □ Services shall be min. 6" diameter. □ Minimum pipe slope shall be 1%. □ Maximum pipe slope shall be 9%.
	Water main loop for large site (as determined by Site Plan Review Committee or by DPW) Water system

Z:\Common\New Engineering\Departments\Site Plan Com\Admin\Checklists\Updated Checklists 2015\Subdivision Plan Checklist - Updates.doc Page 3 of 5

0000	 Show and label service connections for each building. Services shall be HDPE or copper and ¾ inch diameter size min. Show all intersections gated three ways. Hydrants with anchor tee and gates located every 500' min. Show all mainline gates every 1000' min. Fire protection sized for use-Provide calculations if required Foundation Drain (if used) Minimum drain size shall be 6" diameter with a backwater trap Show overflow outfall Preferred discharge is to an infiltration system. Discharge to detention basin or other outfall shall be above the 100 year storm event elevation. Provide stationing for all roadways and sewer or drain cross country runs (typ.) Provide profile for all roadways and sewer or drain cross country runs (typ.) Sections through detention basin(s) Include the following notes: The contractor shall obtain a Street Opening Permit prior to any construction within the City right-of-way All water and sewer material and construction shall conform to the City of Marlborough requirements (see Street Opening Permit) All water and sewer construction shall be inspected by the City Of Marlborough before being backfilled The City shall be notified at least 24 hours prior to the required inspections See Drainage Report Checklist for drainage and detention basin requirements
<u>Laı</u>	ndscape Plan (show appropriate information from Existing Conditions and Construction Plan)
	Proposed landscaping per Buffer and Parking Lot Planting Zoning Requirements Plant and tree legend including species that are proposed to be planted Indicate areas to be loamed and seeded Proposed irrigation (on-site wells to be used unless otherwise approved) Verify sight distances at entrances
<u>Erc</u>	osion Control Plan (show appropriate information from Existing Conditions and Construction Plan)
	Haybale/silt fence combination Anti-tracking area at all construction entrances Protect existing and proposed drainage structures with silt sacks including downstream off site drainage structures that could receive runoff Include the following notes: ☐ All erosion control measures shall be in place prior to construction. Erosion Control shall conform to the City of Marlborough Conservation Commission requirements as stated in the Order of Conditions. Delineate all stockpile areas Provide safety fencing around stockpiles over 10' in height or otherwise restrict site access
De	tail Sheets (typical details) as appropriate
	Pavement Section Detail Sidewalk Detail Curb Detail Driveway Detail Wheel Chair Ramp Detail Concrete Pad Detail Silt Sack Detail Silt Sack Detail Catch Basin Detail* Drainage Manhole with Stair Detail* Culvert section Detail Drain Trench Detail (12" ½" minus gravel backfill envelope-5 feet cover min.) Water Trench Details (12" sand envelope – 5 feet cover min.) Sewer Trench Details (12" ¾ - inch stone envelope) Sewer Manhole Detail (26" cover)

	5' inside Diameter Sewer Manhole with stairs Detail*
	Detention Basin Sections (show section on plan-See also Drainage Report Checklist)
	□ Note provided "As determined necessary by City Engineer to be designed and inspected by a Licensed Professional Geotechnical Engineer and stamped certification of proper design and inspection shall be provided to the City Engineer after installation and prior to as-builts being approved".
	☐ Show Fence with access gate (Outside 10' level area) around detention basin (typ.)
	☐ Show 10 foot wide level access around entire basin for maintenance
	☐ Provide groundwater elevations
	☐ Show providing for 1 foot of freeboard.
	☐ Provide concrete anti-seepage collar in basin berm around discharge pipe
	☐ Impervious core material keyed into existing subgrade within berm
	3:1 basin side slopes
	Detention basin sections from inlet to outlet showing all storm event elevations
	Emergency overflow spillway made of rip rap
_	Basin inlet shall have flared end with rip rap apron
	Outfall Structure Detail
	All outfall elevations
	Show a low flow discharge and grated top
	Provide a trash rack in front of inlet
_	Discharge shall have flared end with rip rap apron
	Miscellaneous Detention Basin Details
	Flared End Detail
	Rip Rap Detail
	Haybale/Silt Fence Detail
	Light Pole Foundation Detail
ш	Retaining Wall Details
	☐ Note: walls over 4' in height shall be permitted through the Building Department Tree/Shrub Planting Detail
	Sign Detail
	Fence Detail
	Flowable Fill Trench
	Pavement Marking Details
	Handicap Parking/Compact Parking Signs
	Water service (note: Curb stops open right) no drip).
	Utility Crossing detail.
	Hydrant Detail anchor tee with gate (Mueller-open right)
	Tapping Sleeve and gate (open right)
	Thrust Block Detail
	Light Pole Foundation Detail
_	
*All	structures shall be raised min 2 course using red clay brick and sealed mortar (typ.) or approved rubber

adjustment rings (min 4" height)